

PREBID QUERIES FOR CURTAINS

Item No.	Description	Pre-Bid Points	Reply
1		Kindly convey - what will be the design of curtains on power track ?	Two / Three pinch / pleats as approved. In case of two/three pinch / pleats, the width of the curtain shall be measured at the bottom of the curtain after hanging in stretched condition.
2		All the fittings - Blind / track - will be on wall or ceiling , if on ceiling POP has to be changed with ply	The curtain shall be provided at the place provided for without damaging the already provided false ceiling / fittings. Damage if any, shall be recified by the agency before claiming the payment.
3		Sheer curtain quantity is not matching with the main curtain .	Quote for the quantity as per tender.
4		Kindly tell the dimensions of the windows for blinds installation. Because we need to understand the width of the blinds, if that needs to be installed at same level or overlapping style .	Roller blinds are meant for the rooms at Admin-faculty building except the front portion of third floor. Tenderers are advised to check the dimensions at site. Where ever more than one blind is approved, an overlap of 150 mm shall be provided .

PREBID QUERIES FOR CURTAINS

5		<p>Roller Blind</p> <ul style="list-style-type: none"> As per the Image-1 selection, this material is currently out of stock in D- Décor Company and will be available only 60 days keeping in mind all specification (Collection, Description, Shade Width, Composition and GSM). 	As per tender conditions
6		<p>Ref Point 2.1 of the schedule</p> <ul style="list-style-type: none"> What is the pattern of the curtain for image 2? Please provide brand and selection details of the Blackout cloth having 280 GSM. 	<p>1). Two/Three pinch / pleats as approved. In case of two/three pinch / pleats, the width of the curtain shall be measured at the bottom of the curtain after hanging in stretched condition.</p> <p>2). Blackout cloth shall be 3 pass, 100% polyester with 280 GSM.</p>
7		<p>Ref Point 2.2 of the schedule</p> <ul style="list-style-type: none"> What is the pattern of the curtain of image 3 Brand and selection details of the Black out cloth having 280 GSM. 	<p>1). Two/Three pinch / pleats as approved. In case of two/three pinch / pleats, the width of the curtain shall be measured at the bottom of the curtain after hanging in stretched condition.</p> <p>2). As per tender condition</p>
8		<p>Ref Point 2.3 of the schedule</p> <ul style="list-style-type: none"> What is the pattern of the curtain of image 4 	Two/Three pinch / pleats as approved. In case of two/three pinch / pleats, the width of the curtain shall be measured at the bottom of the curtain after hanging in stretched condition.
9		<p>Ref Point 2.4 of the schedule</p> <ul style="list-style-type: none"> We want to know the brand of the powder coated aluminum track and also need to understand the weight criteria, is it long with the accessories like supporting brackets, runners, hooks and plastic end caps. 	Good quality and branded track satisfying the specification will be acceptable. However, weight of the aluminium powder coated track should be 435 gm/m. The weight is excluding the accessories like supporting brackets, runners, hooks, endcaps, etc.
10		<p>Stainless Steel Curtain Rod</p> <ul style="list-style-type: none"> We want to know whether curtains are single / double rod, so as to have clarity for quoting price of the supporting / mounting brackets. The schedule doesn't have a separate pricing structure for the supporting / mounting brackets, as such do we need to build the price for the same in the rod? In case of window width being more than 1.8 mtr as per the specification, we would need to provide for center support. Do we need to build the price of the same in the rod? 	<p>1). Single rod</p> <p>2). Please refer the BOQ item, the quoted rates shall be including stainless steel brackets of approved quality.</p> <p>3). Yes</p>

PREBID QUERIES FOR CURTAINS

11		<p>Pelmet</p> <ul style="list-style-type: none">• We want to know the brand of Plywood for quoting the price.• We want to know the brand of Veneer and the its selection details• Kindly specify the finish of the P,U polish• We want to know the brand of synthetic enamel paint the its selection details	<ol style="list-style-type: none">1). Plywood shall be ISI marked, BWR grade (IS 303).2). Selection will be done by EIC. Good quality and branded as per standard practice, veneer shall be used.3). As approved4). Asian, Dulux, Burger, Nerolac
----	--	---	--

Note:- This prebid clarification will form part of the tender document. Rates shall be quoted after taking into consideration of the above modifications.